VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	75 - Mission
School Name:	Cherry Hill Elementary
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes Date of last inspection: 2023-09-25 Date of next inspection:
	Date and type of most recent maintenance: Filters, belts services
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes Detail: Supply air has been increased to its maximum allowable
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes Detail (Including filter grade): MERV-13 filters installed
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No Detail:
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes Detail: Some ESC controls.
Other Relevant Information:	New high efficiency boilers installed this year
District Contact for any Questions:	Name: Dana MacLean Phone Number: 604-850-4193 Email: dana.maclean@mpsd.ca