VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

| School District: | 75 - Mission |
|--|--|
| School Name: | Ferndale/Facilities |
| REQUIREMENT: Regular inspection and maintenance of HVAC systems | Yes/No: Yes Date of last inspection: 2023-08-18 |
| | Date of next inspection: 2024-10-16 Date and type of most recent maintenance: Filter change, replace fan motors on roof |
| RECOMMENDATION: Increase supply of outside air | Yes/No: Yes Detail: Supply air has been increased to its maximum allowable |
| RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible | Yes/No: Yes Detail (Including filter grade): MERV-13 filters installed |
| RECOMMENDATION: Use other air cleaning or treatment technologies | Yes/No: No Detail: |
| RECOMMENDATION: Manage energy use and air distribution through building automation control systems | Yes/No: No Detail: No energy management |
| Other Relevant Information: | Boilers require replacement, have design underway |
| District Contact for any Questions: | Name: Dana MacLean Phone Number: 604-850-4193 |
| | Email: dana.maclean@mpsd.ca |