

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	75 - Mission
School Name:	Christine Morrison Elementary
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2023-09-25
	Date of next inspection: 2023-10-17
	Date and type of most recent maintenance: Upgraded fans and pumps to high efficiency
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes
	Detail: Supply air has been increased to its maximum allowable
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade): MERV-13 filters installed
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: No
	Detail:
Other Relevant Information:	Heat pumps added to heating and cooling system
District Contact for any Questions:	Name: Dana MacLean
	Phone Number: 604-850-4193
	Email: dana.maclean@mpsd.ca